

Copy of Fire Safety Certificate issued by Fire Safety Officer, Surat



rfo-sfps-surat@gujarat.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOSRT/2025/00118972

Date: 23/04/2025

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOSRT/2025/00118972/R1

Building Occupancy/Category: Educational (non-residential)

To,

Sodwadiya Babubhai Rabhubhai

Shri Swaminarayan english medium school cbse At.salvav,Ta.vspi,Dist.valsad Vapi VAPI Valsad 396191

Fire Region: Surat RFO

Mobile No: 9825342902 Email ID: account@ssgsalvav.in

This has reference to your Application No. 2025/00119194 dated 21/04/2025 for Fire Safety Certificate Renewal (FSCR) for the building/premise Shri Swaminarayan english medium school - CBSE (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: Vapi
5. Name of Block(s): mt BNB Swaminarayan pharmacy college , Shri Swaminarayan english medium school CBSE, Shri Swaminarayan english medium school GSEB

The building/premise was inspected on 23/04/2025 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 23/04/2025
2. Six monthly inspection was done on 23/04/2025

The Fire Safety Certificate is renewed for a period of two (2) years upto 23/04/2027 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Hirang Shirishbhai Patel
Fire Safety Officer - General (FSO-G)
2021/001285

Date: 23/04/2025
Time: 01:11 PM



FSCA/O/RFOSRT/2025/00118972/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.


PRINCIPAL
SHREE SWAMINARAYAN ENG.MED.SCHOOL
Salvav


Shree Swaminarayan Shikshan Seva Kendra
Trustee